

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

**Pumps (Multi-stage, centrifugal electric pumps for water supply)**

Name and address of the applicant

ESPA 2025 S.L.  
Crta. Mieres s/n,  
17820 BANYOLES (GIRONA), Spain

Name and address of the manufacturer

same as applicant

Name and address of the factory

same as applicant

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

**Type 230 50 13839/STD:**  
230 V, ~, 50 Hz, 750 W to 1500 W, Class I, IPX5 (MULTI), 40° C, Class F  
**Type 230/400 50:**  
230/400 V, 3~, 50 Hz, 750 W, 900 W, 1100 W, 1500 W, 2200 W, 3000 W,  
4000 W, Class I, IPX5 (MULTI) IPX4 (VE), 40° C, Class F  
**Type 400/692 50:**  
400/692 V, 3~, 50 Hz, 4000 W, 5500 W, 7500 W, 9200 W, 11000 W,  
15000 W, Class I, IPX4 (VE), 40° C, Class F

Trademark (if any)

**ESPA**

Customer's Testing Facility (CTF) Stage used

Stage 1

Model / Type Ref.

**MULTI, VE / 230 50 13839/STD, 230/400 50, 400/692 50**

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60335-1:2010(ed. 5.0) + corrigendum 2010 + Corrigendum 2 - April 2011 + A1:2013 + A2:2016,  
IEC 60335-2-41:2012(ed. 4.0)  
**National Differences:**  
EU Group differences (No specific countries addressed), South Africa (ZA) and United Arab Emirates (AE)

As shown in the Test Report Ref. No. which forms part of this Certificate

2219/0260/1

This CB Test Certificate is issued by the National Certification Body

SGS Belgium NV - Division SGS CEBEC  
Riverside Business Park  
Avenue Internationalelaan 55, Building D  
B-1070 Brussels, Belgium




Signature: Daniel Arranz

Date: 16/06/2020

## Name and address of the factories:

## Additional information:

	Type: 230 50 13839/STD	Type: 230/400 50
Model (s)	MULTI25 3M, MULTI25 4M, MULTI25 5M, MULTI35 3M N, MULTI35 4M N, MULTI35 5M N, MULTI55 3M N	MULTI25 3, MULTI25 4, MULTI25 5, MULTI35 3 N, MULTI35 4 N, MULTI35 5 N, MULTI35 6 N, MULTI35 8 N, MULTI35 10 N, MULTI55 3 N, MULTI55 4 N, MULTI55 6 N, MULTI55 7 N, VE94 5, VE94 6, VE94 7, VE94 8, VE94 9, VE94 10, VE94 11, VE121 2 N
Parameters:		
Rated voltage	230v AC 50Hz	230/400 3AC 50Hz
Rated power	750W – 1500W	750W, 900W, 1100W, 1500W, 2200W, 3000W, 4000W
Protection class	F	F
Protection degree	X5 (MULTI)	X5 (MULTI), X4(VE)
Maximum temperature	40°C	40°C
Throughput capacity	(17-333) l/min	(17- 450)l/min
Minimum height	0,6 m – 22 m	0,7 m – 35 m
Maximum height	42 m – 65 m	42 m – 108 m

	Type: 400/692 50
Model (s)	VE94 12, VE94 13, VE94 14, VE121 3 N, VE121 4 N, VE121 5 N, VE121 6 N, VE121 7 N, VE121 8 N, VE121 9 N, VE121 10 N
Parameters:	
Rated voltage	400/692v 3AC 50Hz
Rated power	4000W – 5500W – 7500W – 9200W – 11000W – 15000W
Protection class	F
Protection degree	X4 (VE)
Maximum temperature	40°C
Throughput capacity	(33 – 450) l/min
Minimum height	40 m – 80m
Maximum height	122 m – 160m

SGS Belgium NV - Division SGS CEBEC  
 Riverside Business Park  
 Avenue Internationalelaan 55, Building D  
 B-1070 Brussels, Belgium




Date: 16/06/2020

Signature: Daniel Arranz