

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 60162578

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*  
0001--IT2235U5 001

Ausstellungsdatum

*Date of Issue*

19.04.2022

(day/mo/yr)

Genehmigungsinhaber *License Holder*

Tecnoplastic S.r.l.  
Via Calabria 3/5  
35020 Saonara PD  
Italia

Fertigungsstätte *Manufacturing Plant*

Tecnoplastic S.r.l.  
Via Calabria 3/5  
35020 Saonara PD  
Italia

Prüfzeichen *Test Mark*



Type Approved  
Safety  
Regular Production  
Surveillance

www.tuv.com  
ID 1111251900

Geprüft nach *Tested acc. to*

EN IEC 60730-2-15:2019  
EN 60730-1:2016+A1

Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

Level Switch Fluid Level Switch (floating switch).

Models : a) CRAB ; b) SNAKE ; c) SPIDER

12

Rated voltage: 12/24 Vdc-VAC or 230 VAC ; 50/60 Hz

Rated current: a) 5 A ; b-c) 10 A

Number of automatic cycles : 1E4

Ambient temperature: a) T50 ; b-c) T40

Prot.-class: Class I

Prot.-kind: IP 68

Trademark: TECNOPLASTIC

Replace Certificate: R 60133272 0001

12

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com  
Fax: +49 221 806-3935

Zertifizierungsstelle



F. Ceriani